



RCRA COMPLIANCE AND ENFORCEMENT BRANCH
ENFORCEMENT CASE RECOMMENDATION

EPA ID NUMBER: 7000585

FACILITY NAME: PEPCO Benning Road
Generating Station

CASE REVIEW OFFICER: Jan Szaro

DATE: July 21, 2010

FINDINGS OF INITIAL CASE REVIEW: Facility was inspected on June 9, 2010 by EPA Contractor. The report noted that there was no documentation of functionality testing of the PLLD for either of the two UST systems.

DISPOSITION RECOMMENDATION: CLOSE

JUSTIFICATION FOR RECOMMENDATION: Contacted Fariba Mahvi of PEPCO on July 12, 2010. Ms. Mahvi provided additional information received on July 20, 2010 that included copies of the most recent passing functionality tests of the PLLDs which was conducted on Aug 27, 2009.

CONCURRENCE SECTION

CASE REVIEW OFFICER

Jan Szaro

DATE: 7/21/10

TEAM LEADER

Melissa Poffel

DATE: 7/22/10

ASSOCIATE DIRECTOR

Carol G. Reed

DATE: 7/22/10